

April 10, 2026

Posted via Ariba
(4 pages)

**ADDENDUM No. 1
REQUEST FOR TENDER No. Doc5601860721
CONTRACT No. 25ECS-MI-04HC**

REVISED SUBMISSION DEADLINE: 12:00 NOON (LOCAL TIME), June 30, 2026

FOR: Highland Creek Treatment Plant Northeast Plant Construction

Please refer to the above Request for Tender document in your possession and be advised of the following:

I. REVISIONS

R1. CLOSING DATE EXTENSION

Please be advised that the closing date has been extended from May 14, 2026 to June 30, 2026 at 12:00 P.M. (Noon) Local Toronto Time

R2. MANDATORY SITE MEETING

The mandatory site visit has been rescheduled from April 17 to April 24.

Date: 24 April, 2026 @ 10:00 AM Local time

Location: Highland Creek Treatment Plant (meet at entrance) at
51 Beechgrove Drive, Scarborough, Toronto

R3. PART 4 – FORM C - EXPERIENCE AND QUALIFICATIONS REQUIREMENTS:

Replace clause 1,a "The General Contractor must have achieved Substantial Performance as defined in the Construction Act for a least three (3) municipal treatment plant projects in North America within the past fifteen (15) years as a General Contractor involving the construction of new or retrofit processes in wastewater or water treatment plants with a treatment capacity of 100 MLD or greater." with **“The General Contractor must have achieved Substantial Performance as defined in the Construction Act for a least three (3) municipal treatment plant projects within the past fifteen (15) years as a General Contractor involving the construction of new or retrofit processes in wastewater or water treatment plants with a treatment capacity of 100 MLD or greater.”**

Part 4 - Form C Experience and Qualifications reflecting above revision R1 has been uploaded/Added into Ariba replacing the previous version.

R4. PART 3 - SPECIFICATIONS AND DRAWINGS

The following drawings have been revised and updated under Addendum No. 1 Drawings. Please access the Go Drive folder via the following link:

- <https://www.cot-sft.goanywhere.cloud:443/link/8bbce778-6ea5-4bcc-ae8-92e0e15d59c6>
- Password: 44LnK4uL4r

Replace Drawing 1020-2025-03-380 Sheet 1-1P401 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-382 Sheet 1-2P401 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-383 Sheet 1-2P402 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-384 Sheet 1-2P403 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-385 Sheet 1-2P431 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-387 Sheet 1-3P106 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-389 Sheet 1-3P303 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-390 Sheet 1-3P401 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-391 Sheet 1-3P402 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-392 Sheet 1-3P403 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-400 Sheet 2-2P401 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-402 Sheet 2-2P403 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-541 Sheet 4-8P101 in its entirety with the revised drawing attached to this addendum.

Replace Drawing 1020-2025-03-543 Sheet 4-8P301 in its entirety with the revised drawing attached to this addendum.

II. ADDITIONS

A1. The structural drawing set was missing from the “IFT – Drawings” folder. These files have been uploaded to **Go Drive** under the “IFT Structural Drawings” folder and can be accessed via the following link:

- <https://www.cot-sft.goanywhere.cloud:443/link/8bbce778-6ea5-4bcc-ae8-92e0e15d59c6>
- Password: 44LnK4uL4r

III. QUESTIONS AND ANSWERS

Q1. We respectfully request clarification on whether the requirement that the General Contractor’s qualifying experience be limited to projects completed in “North America” under Part 4, Form C, Section 1.a could be waived or amended to allow consideration of comparable international projects that meet the same technical, capacity and project value requirements set out in the RFT.

A1. Refer to Addendum 1 item R3. The experience and qualifications requirements have been revised to remove the requirement for North American projects.

Q2. Please clarify the scope of work for this procurement package, the Part 5 Pricing Form refers to specific works (earthworks, pile installation, provisional items and cash allowances) while the specifications (including Section 01010) and drawings refer to other additional items /activities not included in the Pricing Form (example: demolition works, mechanical and electrical works, concrete works, etc)

A2. The pricing form includes links between Part 5 - Instructions to pricing and respective parts of Section 01010. Refer to item 5.2.1.7: "Key Work Milestone B: Completion of new site entrance and access road, construction and commissioning of the new NE Plant, new electrical substation as set out in Specification Section 01010, Paragraph 1.4.B.1 to B.6."

Q3. Drawing 4-3P408 Section 5 calls out Track Covers, TYP. Is this to be considered the same material as the FRP effluent launder covers? Can you please confirm?

A3. The track covers referenced on drawing 4-3P408, Detail 5 is a part of the package provided by the vendor of the Oscillating Sludge Scrapers and Scum Mechanisms (Section 11232) and are not the same materials as the launder covers (Section 06500)

Q4. Can you please confirm if the material for the scum baffle and the scum baffle wall in the secondary clarifiers are the same?

A4. The scum baffles identified in Section 11232, Section 11236, and Section 11342 are to be constructed using the materials as specified in their respective sections. The baffles identified in Section 11232 indicates 304L, Sections 11236 and 11342 indicate 316.

Suppliers must acknowledge receipt of all addenda in the space provided on Part 4 – Submission Form as per Part 1 Tender Process, Section 1 RFT Specific Process and Submission Instructions, Item 1.7 – Addenda, of the Tender document. All other aspects of the Tender remain the same.

Should you have any questions regarding this addendum send via the event message board or contact Kenan Bachir at Kenan.Bachir@toronto.ca

Yours truly,

Valbona Tuzi, Supervisor
Infrastructure & Development Services
Purchasing Client Services
Purchasing and Materials Management Division